
May 9, 2024

Mr. Kamran Yazdidoost
City of Seattle
Seattle Department of Construction and Inspections
700 Fifth Ave, Suite 2000
P.O. Box 34019
Seattle, WA 98124-4996

Subject: Project #6757678-CN- S33 Aurora; Seattle, WA
Building Permit Post Permit Revision Narrative

Dear Mr. Yazdidoost:

As discussed over email, revisions have been made to the proposed detention system, which requires a post permit revision. We have prepared the narrative below to describe the revisions. Please feel free to contact me with any questions or coordination items you have.

Revisions

Civil Plans

Sheet C3.01- Drainage and Wastewater Control Plan

1. The 24" DuroMaxx connector pipes from the 96" pipe to the upstream and downstream manhole are adjusted to the minimum 30" pipe manufactured by Contech.
2. IEs of the upstream and downstream connector pipes are adjusted to two inches above the 96" IE to meet Contech manufacturing requirements.
3. The control structure outlet is revised to a 12" to match the control structure riser.

Sheet C3.10- Drainage Details

1. Details 1 and 2 are updated to reflect the 30" DuroMaxx connector pipe updates and revised IEs to meet Contech manufacturing requirements.

Kamran, should you have any questions regarding the revisions contained herein, please do not hesitate to contact me at 425.458.7898 or at my email address below. Thank you for your review.

Sincerely,

Navix Engineering, Inc.

A handwritten signature in black ink that reads "Tyler Loudon". The signature is written in a cursive, flowing style.

Tyler Loudon, P.E.
Project Manager
tloudon@navixeng.com