

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Shelter 9221 14th Ave NW Units 1 & 10
 9221 / 9223 14th Ave NW
 Seattle, WA 98117

Contact Information

Vandervort Architects -Mark Wierenga
 2000 Fairview AVE E - Suite 103
 Seattle, WA 98102

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

Instructions Seattle: Sea-Tac AP

Design Temperature Difference (ΔT) 46
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

Instructions Conditioned Floor Area (sq ft) 1,453

Average Ceiling Height

Instructions Average Ceiling Height (ft) 8.5

Conditioned Volume 12,351

Glazing and Doors

Instructions U-0.28

U-Factor X Area = UA
 0.280 X 417 = 116.76

Skylights

Instructions

U-Factor X Area = UA
 0.50 X 0 = ---

Insulation

Attic

Instructions Select R-Value

U-Factor X Area = UA
 No selection X 0 = ---

Single Rafter or Joist Vaulted Ceilings

Instructions R-49 Advanced

U-Factor X Area = UA
 0.020 X 463 = 9.26

Above Grade Walls (see Figure 1)

Instructions R-21 Intermediate

U-Factor X Area = UA
 0.056 X 1,586 = 88.82

Floors

Instructions R-38

U-Factor X Area = UA
 0.025 X 464 = 11.60

Below Grade Walls (see Figure 1)

Instructions No Below Grade Walls in this project.

U-Factor X Area = UA
 0.028 X 0 = ---

Slab Below Grade (see Figure 1)

Instructions No Slab Below Grade in this project.

F-Factor X Length = UA
 0.303 X 0 = ---

Slab on Grade (see Figure 1)

Instructions No Slab on Grade in this project.

F-Factor X Length = UA
 --- X 0 = ---

Location of Ducts

Instructions No Ducts

Duct Leakage Coefficient 1.00

Sum of UA 226.44

Envelope Heat Load 10,416 Btu / Hour

Sum of UA x ΔT

Air Leakage Heat Load 6,136 Btu / Hour

Volume x 0.6 x ΔT x 0.018

Building Design Heat Load 16,552 Btu / Hour

Air leakage + envelope heat loss

Building and Duct Heat Load 16,552 Btu / Hour

Ducts in unconditioned space: sum of building heat loss x 1.10


Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 20,690 Btu / Hour

Building and duct heat loss x 1.40 for forced air furnace

Building and duct heat loss x 1.25 for heat pump

Figure 1.



Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Shelter 9221 14th Ave NW Units 2 & 9
 9221 / 9223 14th Ave NW
 Seattle, WA 98117

Contact Information

Vandervort Architects -Mark Wierenga
 2000 Fairview AVE E - Suite 103
 Seattle, WA 98102

Heating System Type:

All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference (ΔT)
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

46

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

1,457

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.5

Conditioned Volume
 12,385

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
 0.280 X 296 = 82.88

Skylights

[Instructions](#)

U-Factor X Area = UA
 0.50 X 0 = ---

Insulation

Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA
 No selection X 0 = ---

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-49 Advanced

U-Factor X Area = UA
 0.020 X 466 = 9.32

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 1,221 = 68.38

Floors

[Instructions](#)

R-38

U-Factor X Area = UA
 0.025 X 466 = 11.65

Below Grade Walls (see Figure 1)

[Instructions](#)

No Below Grade Walls in this project.

U-Factor X Area = UA
 0.028 X 0 = ---

Slab Below Grade (see Figure 1)

[Instructions](#)

No Slab Below Grade in this project.

F-Factor X Length = UA
 0.303 X 0 = ---

Slab on Grade (see Figure 1)

[Instructions](#)

No Slab on Grade in this project.

F-Factor X Length = UA
 --- X 0 = ---

Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient
 1.00

Sum of UA 172.23

Envelope Heat Load 7,922 Btu / Hour

Sum of UA x ΔT

Air Leakage Heat Load 6,153 Btu / Hour

Volume x 0.6 x ΔT x 0.018

Building Design Heat Load 14,075 Btu / Hour

Air leakage + envelope heat loss

Building and Duct Heat Load 14,075 Btu / Hour

Ducts in unconditioned space: sum of building heat loss x 1.10


Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 17,594 Btu / Hour

Building and duct heat loss x 1.40 for forced air furnace

Building and duct heat loss x 1.25 for heat pump

Figure 1.



Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Shelter 9221 14th Ave NW Units 2a, 5a, 9a
 9221 / 9223 14th Ave NW
 Seattle, WA 98117

Contact Information

Vandervort Architects -Mark Wierenga
 2000 Fairview AVE E - Suite 103
 Seattle, WA 98102

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference (ΔT) 46
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft) 675

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft) 8.5

Conditioned Volume 5,738

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
 0.280 X 148 = 41.44

Skylights

[Instructions](#)

U-Factor X Area = UA
 0.50 X 0 = ---

Insulation

Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA
 No selection X 0 = ---

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-49 Advanced

U-Factor X Area = UA
 0.020 X 351 = 7.02

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 366 = 20.50

Floors

[Instructions](#)

R-38

U-Factor X Area = UA
 0.025 X 351 = 8.78

Below Grade Walls (see Figure 1)

[Instructions](#)

No Below Grade Walls in this project.

U-Factor X Area = UA
 0.028 X 0 = ---

Slab Below Grade (see Figure 1)

[Instructions](#)

No Slab Below Grade in this project.

F-Factor X Length = UA
 0.303 X 0 = ---

Slab on Grade (see Figure 1)

[Instructions](#)

No Slab on Grade in this project.

F-Factor X Length = UA
 --- X 0 = ---

Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient
 1.00

Sum of UA 77.73

Envelope Heat Load 3,576 Btu / Hour
 $\text{Sum of UA} \times \Delta T$


Air Leakage Heat Load 2,850 Btu / Hour
 $\text{Volume} \times 0.6 \times \Delta T \times 0.018$

Building Design Heat Load 6,426 Btu / Hour
 Air leakage + envelope heat loss

Building and Duct Heat Load 6,426 Btu / Hour
 Ducts in unconditioned space: sum of building heat loss x 1.10
 Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 8,033 Btu / Hour
 Building and duct heat loss x 1.40 for forced air furnace
 Building and duct heat loss x 1.25 for heat pump

Figure 1.



Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Shelter 9221 14th Ave NW Units 3 & 4
 9221 / 9223 14th Ave NW
 Seattle, WA 98117

Contact Information

Vandervort Architects -Mark Wierenga
 2000 Fairview AVE E - Suite 103
 Seattle, WA 98102

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference (ΔT) 46
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft) 1,322

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft) 8.5

Conditioned Volume 11,237

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
 0.280 X 359 = 100.52

Skylights

[Instructions](#)

U-Factor X Area = UA
 0.50 X 0 = ---

Insulation

Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA
 No selection X 0 = ---

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-49 Advanced

U-Factor X Area = UA
 0.020 X 528 = 10.56

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 2,078 = 116.37

Floors

[Instructions](#)

R-38

U-Factor X Area = UA
 0.025 X 427 = 10.68

Below Grade Walls (see Figure 1)

[Instructions](#)

No Below Grade Walls in this project.

U-Factor X Area = UA
 0.028 X 0 = ---

Slab Below Grade (see Figure 1)

[Instructions](#)

No Slab Below Grade in this project.

F-Factor X Length = UA
 0.303 X 0 = ---

Slab on Grade (see Figure 1)

[Instructions](#)

No Slab on Grade in this project.

F-Factor X Length = UA
 --- X 0 = ---

Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient
 1.00

Sum of UA 238.12

Envelope Heat Load 10,954 Btu / Hour
 $\text{Sum of UA} \times \Delta T$

Air Leakage Heat Load 5,583 Btu / Hour
 $\text{Volume} \times 0.6 \times \Delta T \times 0.018$

Building Design Heat Load 16,536 Btu / Hour
 Air leakage + envelope heat loss

Building and Duct Heat Load 16,536 Btu / Hour

Ducts in unconditioned space: sum of building heat loss x 1.10


Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 20,670 Btu / Hour

Building and duct heat loss x 1.40 for forced air furnace

Building and duct heat loss x 1.25 for heat pump

Figure 1.



Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Shelter 9221 14th Ave NW Units 4a
 9221 / 9223 14th Ave NW
 Seattle, WA 98117

Contact Information

Vandervort Architects -Mark Wierenga
 2000 Fairview AVE E - Suite 103
 Seattle, WA 98102

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference (ΔT) 46
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft) 702

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft) 8.5

Conditioned Volume 5,967

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
 0.280 X 211 = 59.08

Skylights

[Instructions](#)

U-Factor X Area = UA
 0.50 X 0 = ---

Insulation

Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA
 No selection X 0 = ---

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-49 Advanced

U-Factor X Area = UA
 0.020 X 359 = 7.18

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 876 = 49.06

Floors

[Instructions](#)

R-38

U-Factor X Area = UA
 0.025 X 359 = 8.98

Below Grade Walls (see Figure 1)

[Instructions](#)

No Below Grade Walls in this project.

U-Factor X Area = UA
 0.028 X 0 = ---

Slab Below Grade (see Figure 1)

[Instructions](#)

No Slab Below Grade in this project.

F-Factor X Length = UA
 0.303 X 0 = ---

Slab on Grade (see Figure 1)

[Instructions](#)

No Slab on Grade in this project.


F-Factor X Length = UA
 --- X 0 = ---

Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient 1.00



Sum of UA	124.29
Envelope Heat Load	5,717 Btu / Hour
<i>Sum of UA x ΔT</i>	
Air Leakage Heat Load	2,964 Btu / Hour
<i>Volume x 0.6 x ΔT x 0.018</i>	
Building Design Heat Load	8,682 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
Building and Duct Heat Load	8,682 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
Maximum Heat Equipment Output	10,852 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Shelter 9221 14th Ave NW Units 5 & 6
 9221 / 9223 14th Ave NW
 Seattle, WA 98117

Contact Information

Vandervort Architects -Mark Wierenga
 2000 Fairview AVE E - Suite 103
 Seattle, WA 98102

Heating System Type:

All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

Instructions

Seattle: Sea-Tac AP

Design Temperature Difference (ΔT)
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

46

Area of Building

Conditioned Floor Area

Instructions

Conditioned Floor Area (sq ft)

1,637

Average Ceiling Height

Instructions

Average Ceiling Height (ft)

8.5

Conditioned Volume
 13,915

Glazing and Doors

Instructions

U-0.28

U-Factor X Area = UA
 0.280 X 379 = 106.12

Skylights

Instructions

U-Factor X Area = UA
 0.50 X 0 = ---

Insulation

Attic

Instructions

Select R-Value

U-Factor X Area = UA
 No selection X 0 = ---

Single Rafter or Joist Vaulted Ceilings

Instructions

R-49 Advanced

U-Factor X Area = UA
 0.020 X 607 = 12.14

Above Grade Walls (see Figure 1)

Instructions

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 2,446 = 136.98

Floors

Instructions

R-38

U-Factor X Area = UA
 0.025 X 607 = 15.18

Below Grade Walls (see Figure 1)

Instructions

No Below Grade Walls in this project.

U-Factor X Area = UA
 0.028 X 0 = ---

Slab Below Grade (see Figure 1)

Instructions

No Slab Below Grade in this project.

F-Factor X Length = UA
 0.303 X 0 = ---

Slab on Grade (see Figure 1)

Instructions

No Slab on Grade in this project.

F-Factor X Length = UA
 --- X 0 = ---

Location of Ducts


Instructions

No Ducts

Duct Leakage Coefficient
 1.00

Sum of UA	270.41
Envelope Heat Load	12,439 Btu / Hour
<i>Sum of UA x ΔT</i>	
Air Leakage Heat Load	6,913 Btu / Hour
<i>Volume x 0.6 x ΔT x 0.018</i>	
Building Design Heat Load	19,352 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
Building and Duct Heat Load	19,352 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
Maximum Heat Equipment Output	24,190 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	

Figure 1.



Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Shelter 9221 14th Ave NW Units 6a
 9221 / 9223 14th Ave NW
 Seattle, WA 98117

Contact Information

Vandervort Architects -Mark Wierenga
 2000 Fairview AVE E - Suite 103
 Seattle, WA 98102

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference (ΔT) 46
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft) 670

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft) 8.5

Conditioned Volume 5,695

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
 0.280 X 171 = 47.88

Skylights

[Instructions](#)

0.50

U-Factor X Area = UA
 0.50 X 0 = ---

Insulation

Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA
 No selection X 0 = ---

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-49 Advanced

U-Factor X Area = UA
 0.020 X 534 = 10.68

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 559 = 31.30

Floors

[Instructions](#)

R-38

U-Factor X Area = UA
 0.025 X 534 = 13.35

Below Grade Walls (see Figure 1)

[Instructions](#)

No Below Grade Walls in this project.

U-Factor X Area = UA
 0.028 X 0 = ---

Slab Below Grade (see Figure 1)

[Instructions](#)

No Slab Below Grade in this project.

F-Factor X Length = UA
 0.303 X 0 = ---

Slab on Grade (see Figure 1)

[Instructions](#)

No Slab on Grade in this project.

F-Factor X Length = UA
 --- X 0 = ---

Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient
 1.00

Sum of UA 103.21

Envelope Heat Load 4,748 Btu / Hour

Sum of UA x ΔT

Air Leakage Heat Load 2,829 Btu / Hour

Volume x 0.6 x ΔT x 0.018

Building Design Heat Load 7,577 Btu / Hour

Air leakage + envelope heat loss

Building and Duct Heat Load 7,577 Btu / Hour

Ducts in unconditioned space: sum of building heat loss x 1.10


Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 9,471 Btu / Hour

Building and duct heat loss x 1.40 for forced air furnace

Building and duct heat loss x 1.25 for heat pump

Figure 1.



Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Shelter 9221 14th Ave NW Units 7
 9221 / 9223 14th Ave NW
 Seattle, WA 98117

Contact Information

Vandervort Architects -Mark Wierenga
 2000 Fairview AVE E - Suite 103
 Seattle, WA 98102

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference (ΔT) 46
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft) 1,589

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft) 8.5

Conditioned Volume 13,507

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
 0.280 X 437 = 122.36

Skylights

[Instructions](#)

U-Factor X Area = UA
 0.50 X 0 = ---

Insulation

Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA
 No selection X 0 = ---

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-49 Advanced

U-Factor X Area = UA
 0.020 X 586 = 11.72

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 2,244 = 125.66

Floors

[Instructions](#)

R-38

U-Factor X Area = UA
 0.025 X 586 = 14.65

Below Grade Walls (see Figure 1)

[Instructions](#)

No Below Grade Walls in this project.

U-Factor X Area = UA
 0.028 X 0 = ---

Slab Below Grade (see Figure 1)

[Instructions](#)

No Slab Below Grade in this project.

F-Factor X Length = UA
 0.303 X 0 = ---

Slab on Grade (see Figure 1)

[Instructions](#)

No Slab on Grade in this project.

F-Factor X Length = UA
 --- X 0 = ---

Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient
 1.00

Sum of UA 274.39

Envelope Heat Load 12,622 Btu / Hour
 $\text{Sum of UA} \times \Delta T$


Air Leakage Heat Load 6,710 Btu / Hour
 $\text{Volume} \times 0.6 \times \Delta T \times 0.018$

Building Design Heat Load 19,332 Btu / Hour
 Air leakage + envelope heat loss

Building and Duct Heat Load 19,332 Btu / Hour
 Ducts in unconditioned space: sum of building heat loss x 1.10
 Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 24,165 Btu / Hour
 Building and duct heat loss x 1.40 for forced air furnace
 Building and duct heat loss x 1.25 for heat pump

Figure 1.



Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Shelter 9221 14th Ave NW Units 8
 9221 / 9223 14th Ave NW
 Seattle, WA 98117

Contact Information

Vandervort Architects -Mark Wierenga
 2000 Fairview AVE E - Suite 103
 Seattle, WA 98102

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference (ΔT) 46
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft) 1,563

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft) 8.5

Conditioned Volume 13,286

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
 0.280 X 385 = 107.80

Skylights

[Instructions](#)

U-Factor X Area = UA
 0.50 X 0 = ---

Insulation

Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA
 No selection X 0 = ---

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-49 Advanced

U-Factor X Area = UA
 0.020 X 519 = 10.38

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 2,228 = 124.77

Floors

[Instructions](#)

R-38

U-Factor X Area = UA
 0.025 X 519 = 12.98

Below Grade Walls (see Figure 1)

[Instructions](#)

No Below Grade Walls in this project.

U-Factor X Area = UA
 0.028 X 0 = ---

Slab Below Grade (see Figure 1)

[Instructions](#)

No Slab Below Grade in this project.

F-Factor X Length = UA
 0.303 X 0 = ---

Slab on Grade (see Figure 1)

[Instructions](#)

No Slab on Grade in this project.

F-Factor X Length = UA
 --- X 0 = ---

Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient
 1.00

Sum of UA 255.92

Envelope Heat Load 11,772 Btu / Hour
 $\text{Sum of UA} \times \Delta T$


Air Leakage Heat Load 6,600 Btu / Hour
 $\text{Volume} \times 0.6 \times \Delta T \times 0.018$

Building Design Heat Load 18,373 Btu / Hour
 $\text{Air leakage} + \text{envelope heat loss}$

Building and Duct Heat Load 18,373 Btu / Hour
 $\text{Ducts in unconditioned space: sum of building heat loss} \times 1.10$
 $\text{Ducts in conditioned space: sum of building heat loss} \times 1$

Maximum Heat Equipment Output 22,966 Btu / Hour
 $\text{Building and duct heat loss} \times 1.40 \text{ for forced air furnace}$
 $\text{Building and duct heat loss} \times 1.25 \text{ for heat pump}$

Figure 1.



Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Shelter 9221 14th Ave NW Units 11 & 12
 9221 / 9223 14th Ave NW
 Seattle, WA 98117

Contact Information

Vandervort Architects -Mark Wierenga
 2000 Fairview AVE E - Suite 103
 Seattle, WA 98102

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

Instructions Seattle: Sea-Tac AP

Design Temperature Difference (ΔT) 46
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

Instructions Conditioned Floor Area (sq ft) 1,870

Average Ceiling Height

Instructions Average Ceiling Height (ft) 8.5

Conditioned Volume 15,895

Glazing and Doors

Instructions U-0.28

U-Factor X Area = UA
 0.280 X 534 = 149.52

Skylights

Instructions

U-Factor X Area = UA
 0.50 X 0 = ---

Insulation

Attic

Instructions Select R-Value

U-Factor X Area = UA
 No selection X 0 = ---

Single Rafter or Joist Vaulted Ceilings

Instructions R-49 Advanced

U-Factor X Area = UA
 0.020 X 598 = 11.96

Above Grade Walls (see Figure 1)

Instructions R-21 Intermediate

U-Factor X Area = UA
 0.056 X 1,956 = 109.54

Floors

Instructions R-38

U-Factor X Area = UA
 0.025 X 598 = 14.95

Below Grade Walls (see Figure 1)

Instructions No Below Grade Walls in this project.

U-Factor X Area = UA
 0.028 X 0 = ---

Slab Below Grade (see Figure 1)

Instructions No Slab Below Grade in this project.

F-Factor X Length = UA
 0.303 X 0 = ---

Slab on Grade (see Figure 1)

Instructions No Slab on Grade in this project.

F-Factor X Length = UA
 --- X 0 = ---

Location of Ducts

Instructions No Ducts

Duct Leakage Coefficient
 1.00

Sum of UA	285.97
Envelope Heat Load	13,154 Btu / Hour
<i>Sum of UA x ΔT</i>	
Air Leakage Heat Load	7,897 Btu / Hour
<i>Volume x 0.6 x ΔT x 0.018</i>	
Building Design Heat Load	21,051 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
Building and Duct Heat Load	21,051 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
Maximum Heat Equipment Output	26,314 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	

Figure 1.

