



# Project #6769232-PH Yesler Towers Phase 1 Permit Revision 01

---

*Date:* May 25, 2022  
*To:* Viktor Peykov, Seattle Department of Construction and Inspections  
*From:* Brady Retzlaff, KPFF Consulting Engineers  
*Subject:* Project #676932-PH, Revision 01; Summary of Changes

---

The purpose of this memo is to describe the revisions that are proposed to the drainage design for Project #6769232-PH, at 803 South Washington Street.

## Sheet C400: Grading, Drainage & Utility Plan

- Detail B, *Detention Vault Plan Enlargement* has been revised to show the relocation of a detention vault access hatch to the back wall of the vault. Per coordination with the reviewer, this change is acceptable provided that the hatch is still within 25 feet of the vault inlet pipes. Dimensions have been provided to show compliance with this parameter.
- Note 4 has been revised to indicate that detention vault access hatches must be located within 25 feet of the vault inlet pipes, as coordinated with the reviewer.

If you have any questions concerning the revision, please call me at (206) 926-0725.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Brady Retzlaff', with a stylized, overlapping flourish at the end.

Brady Retzlaff