

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Townhouse Unit 2, 1726 19th Ave
Seattle, WA 98122
6701530-CN

Contact Information

Brad Khouri, b9 Architects
610 2nd Avenue
Seattle, WA 98104

Heating System Type:

☐ All Other Systems

☒ Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference (ΔT)

46

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

1,993

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.1

Conditioned Volume

16,143

Glazing and Doors

[Instructions](#)

U-0.24

U-Factor	X	Area	=	UA
0.240		419		100.56

Skylights

[Instructions](#)

U-Factor	X	Area	=	UA
0.50		8		4.00

Insulation

Attic

[Instructions](#)

Select R-Value

U-Factor	X	Area	=	UA
No selection				---

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

U-Factor	X	Area	=	UA
0.027		513		13.85

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor	X	Area	=	UA
0.056		1,254		70.22

Floors

[Instructions](#)

R-38

U-Factor	X	Area	=	UA
0.025		521		13.03

Below Grade Walls (see Figure 1)

[Instructions](#)

No Below Grade Walls in th

U-Factor	X	Area	=	UA
0.028				

Slab Below Grade (see Figure 1)

[Instructions](#)

No Slab Below Grade in th

F-Factor	X	Length	=	UA
0.303				---

Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Fully Insulated

F-Factor	X	Length	=	UA
0.360				

Location of Ducts


[Instructions](#)

Conditioned Space

Duct Leakage Coefficient

1.00

Figure 1.



Sum of UA	201.66
Envelope Heat Load	9,276 Btu / Hour
<i>Sum of UA x ΔT</i>	
Air Leakage Heat Load	8,020 Btu / Hour
<i>Volume x 0.6 x ΔT x 0.018</i>	
Building Design Heat Load	17,296 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
Building and Duct Heat Load	17,296 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
Maximum Heat Equipment Output	21,620 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	