

## Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at [energycode@energy.wsu.edu](mailto:energycode@energy.wsu.edu) or (360) 956-2042 for assistance.

### Project Information

6717 42ND AVE S - RH19  
SEATTLE, WA 98118  
6848602-CN

### Contact Information

JW ARCHITECTS  
1257 S KING ST, SEATTLE, WA  
(206) 953-1305

### Heating System Type:

☐ All Other Systems

☒ Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

### Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference ( $\Delta T$ )

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

46

### Area of Building

#### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

1,511

#### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.5

Conditioned Volume

12,844

### Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA  
0.280 X 419 = 117.37

U-Factor X Area = UA  
0.50 X 0 = ---

### Skylights

[Instructions](#)

### Insulation

#### Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA  
No selection X 0 = ---

#### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

U-Factor X Area = UA  
0.027 X 622 = 16.78

#### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA  
0.056 X 2,580 = 144.50

#### Floors

[Instructions](#)

R-38

U-Factor X Area = UA  
0.025 X 16 = 0.39

#### Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

U-Factor X Area = UA  
0.042 X 147 = 6.15

#### Slab Below Grade (see Figure 1)

[Instructions](#)

R-21 int Plus R-5 ci

F-Factor X Length = UA  
0.303 X 51 = 15.45

#### Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Fully Insulated

F-Factor X Length = UA  
0.360 X 56 = 20.16

### Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient

1.00

Sum of UA 320.81

Envelope Heat Load 14,757 Btu / Hour

Sum of UA x  $\Delta T$

Air Leakage Heat Load 6,381 Btu / Hour

Volume x 0.6 x  $\Delta T$  x 0.018

Building Design Heat Load 21,138 Btu / Hour

Air leakage + envelope heat loss

Building and Duct Heat Load 21,138 Btu / Hour

Ducts in unconditioned space: sum of building heat loss x 1.10


Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 26,422 Btu / Hour

Building and duct heat loss x 1.40 for forced air furnace

Building and duct heat loss x 1.25 for heat pump

Figure 1.



## Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at [energycode@energy.wsu.edu](mailto:energycode@energy.wsu.edu) or (360) 956-2042 for assistance.

### Project Information

6717 42ND AVE S - RH20  
SEATTLE, WA 98118  
6848602-CN

### Contact Information

JW ARCHITECTS  
1257 S KING ST, SEATTLE, WA  
(206) 953-1305

### Heating System Type:

☐ All Other Systems

☒ Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

### Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference ( $\Delta T$ )

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

46

### Area of Building

#### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

1,531

#### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.5

Conditioned Volume

13,014

### Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA  
0.280 X 413 = 115.62

U-Factor X Area = UA  
0.50 X 0 = ---

### Skylights

[Instructions](#)

### Insulation

#### Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA  
No selection X 0 = ---

#### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

U-Factor X Area = UA  
0.027 X 627 = 16.93

#### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA  
0.056 X 2,489 = 139.41

#### Floors

[Instructions](#)

R-38

U-Factor X Area = UA  
0.025 X 20 = 0.51

#### Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

U-Factor X Area = UA  
0.042 X 160 = 6.70

#### Slab Below Grade (see Figure 1)

[Instructions](#)

R-21 int Plus R-5 ci

F-Factor X Length = UA  
0.303 X 53 = 15.91

#### Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Fully Insulated

F-Factor X Length = UA  
0.360 X 53 = 18.90

### Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient

1.00

Sum of UA 313.97

Envelope Heat Load 14,443 Btu / Hour

Sum of UA x  $\Delta T$

Air Leakage Heat Load 6,465 Btu / Hour

Volume x 0.6 x  $\Delta T$  x 0.018

Building Design Heat Load 20,908 Btu / Hour

Air leakage + envelope heat loss

Building and Duct Heat Load 20,908 Btu / Hour

Ducts in unconditioned space: sum of building heat loss x 1.10


Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 26,135 Btu / Hour

Building and duct heat loss x 1.40 for forced air furnace

Building and duct heat loss x 1.25 for heat pump

Figure 1.



## Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at [energycode@energy.wsu.edu](mailto:energycode@energy.wsu.edu) or (360) 956-2042 for assistance.

### Project Information

6717 42ND AVE S - RH21  
SEATTLE, WA 98118  
6848602-CN

### Contact Information

JW ARCHITECTS  
1257 S KING ST, SEATTLE, WA  
(206) 953-1305

### Heating System Type:

☐ All Other Systems

☒ Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

### Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference ( $\Delta T$ )

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

46

### Area of Building

#### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

1,531

#### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.5

Conditioned Volume

13,014

### Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA  
0.280 X 391 = 109.36

U-Factor X Area = UA  
0.50 X 0 = ---

### Skylights

[Instructions](#)

### Insulation

#### Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA  
No selection X 0 = ---

#### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

U-Factor X Area = UA  
0.027 X 538 = 14.54

#### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA  
0.056 X 2,527 = 141.51

#### Floors

[Instructions](#)

R-38

U-Factor X Area = UA  
0.025 X 11 = 0.26

#### Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

U-Factor X Area = UA  
0.042 X 704 = 29.56

#### Slab Below Grade (see Figure 1)

[Instructions](#)

R-21 int Plus R-5 ci

F-Factor X Length = UA  
0.303 X 86 = 25.91

#### Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Fully Insulated

F-Factor X Length = UA  
0.360 X 28 = 9.90

### Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient

1.00

Sum of UA 331.03

Envelope Heat Load 15,227 Btu / Hour

Sum of UA x  $\Delta T$

Air Leakage Heat Load 6,465 Btu / Hour

Volume x 0.6 x  $\Delta T$  x 0.018

Building Design Heat Load 21,692 Btu / Hour

Air leakage + envelope heat loss

Building and Duct Heat Load 21,692 Btu / Hour

Ducts in unconditioned space: sum of building heat loss x 1.10


Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 27,116 Btu / Hour

Building and duct heat loss x 1.40 for forced air furnace

Building and duct heat loss x 1.25 for heat pump

Figure 1.



## Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at [energycode@energy.wsu.edu](mailto:energycode@energy.wsu.edu) or (360) 956-2042 for assistance.

### Project Information

6717 42ND AVE S - RH22  
SEATTLE, WA 98118  
6848602-CN

### Contact Information

JW ARCHITECTS  
1257 S KING ST, SEATTLE, WA  
(206) 953-1305

### Heating System Type:

☐ All Other Systems

☒ Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

### Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference ( $\Delta T$ )

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

46

### Area of Building

#### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

1,993

#### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.5

Conditioned Volume

16,941

### Glazing and Doors

[Instructions](#)

U-0.28

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| 0.280           |          | 462         |          | 129.41    |

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| 0.50            |          | 0           |          | ---       |

### Skylights

[Instructions](#)

### Insulation

#### Attic

[Instructions](#)

Select R-Value

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| No selection    |          | 0           |          | ---       |

#### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| 0.027           |          | 619         |          | 16.71     |

#### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| 0.056           |          | 2,655       |          | 148.65    |

#### Floors

[Instructions](#)

R-38

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| 0.025           |          | 20          |          | 0.49      |

#### Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| 0.042           |          | 133         |          | 5.60      |

#### Slab Below Grade (see Figure 1)

[Instructions](#)

R-21 int Plus R-5 ci

|                 |          |               |          |           |
|-----------------|----------|---------------|----------|-----------|
| <b>F-Factor</b> | <b>X</b> | <b>Length</b> | <b>=</b> | <b>UA</b> |
| 0.303           |          | 39            |          | 11.82     |

#### Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Fully Insulated

|                 |          |               |          |           |
|-----------------|----------|---------------|----------|-----------|
| <b>F-Factor</b> | <b>X</b> | <b>Length</b> | <b>=</b> | <b>UA</b> |
| 0.360           |          | 73            |          | 26.28     |

### Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient

1.00

**Sum of UA** 338.96

**Envelope Heat Load** 15,592 Btu / Hour

*Sum of UA x  $\Delta T$*

**Air Leakage Heat Load** 8,416 Btu / Hour

*Volume x 0.6 x  $\Delta T$  x 0.018*

**Building Design Heat Load** 24,008 Btu / Hour

*Air leakage + envelope heat loss*

**Building and Duct Heat Load** 24,008 Btu / Hour

*Ducts in unconditioned space: sum of building heat loss x 1.10*


*Ducts in conditioned space: sum of building heat loss x 1*

**Maximum Heat Equipment Output** 30,010 Btu / Hour

*Building and duct heat loss x 1.40 for forced air furnace*

*Building and duct heat loss x 1.25 for heat pump*

Figure 1.



## Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at [energycode@energy.wsu.edu](mailto:energycode@energy.wsu.edu) or (360) 956-2042 for assistance.

### Project Information

6717 42ND AVE S - RH23  
SEATTLE, WA 98118  
6848602-CN

### Contact Information

JW ARCHITECTS  
1257 S KING ST, SEATTLE, WA  
(206) 953-1305

### Heating System Type:

☐ All Other Systems

☒ Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

### Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference ( $\Delta T$ )

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

46

### Area of Building

#### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

1,659

#### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.5

Conditioned Volume

14,102

### Glazing and Doors

[Instructions](#)

U-0.28

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| 0.280           |          | 504         |          | 141.07    |

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| 0.50            |          | 0           |          | ---       |

### Skylights

[Instructions](#)

### Insulation

#### Attic

[Instructions](#)

Select R-Value

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| No selection    |          | 0           |          | ---       |

#### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| 0.027           |          | 608         |          | 16.42     |

#### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| 0.056           |          | 2,609       |          | 146.09    |

#### Floors

[Instructions](#)

R-38

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| 0.025           |          | 15          |          | 0.38      |

#### Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

|                 |          |             |          |           |
|-----------------|----------|-------------|----------|-----------|
| <b>U-Factor</b> | <b>X</b> | <b>Area</b> | <b>=</b> | <b>UA</b> |
| 0.042           |          | 326         |          | 13.70     |

#### Slab Below Grade (see Figure 1)

[Instructions](#)

R-21 int Plus R-5 ci

|                 |          |               |          |           |
|-----------------|----------|---------------|----------|-----------|
| <b>F-Factor</b> | <b>X</b> | <b>Length</b> | <b>=</b> | <b>UA</b> |
| 0.303           |          | 47            |          | 14.33     |

#### Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Fully Insulated

|                 |          |               |          |           |
|-----------------|----------|---------------|----------|-----------|
| <b>F-Factor</b> | <b>X</b> | <b>Length</b> | <b>=</b> | <b>UA</b> |
| 0.360           |          | 65            |          | 23.29     |

### Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient

1.00

**Sum of UA** 355.28

**Envelope Heat Load** 16,343 Btu / Hour

*Sum of UA x  $\Delta T$*

**Air Leakage Heat Load** 7,006 Btu / Hour

*Volume x 0.6 x  $\Delta T$  x 0.018*

**Building Design Heat Load** 23,348 Btu / Hour

*Air leakage + envelope heat loss*

**Building and Duct Heat Load** 23,348 Btu / Hour

*Ducts in unconditioned space: sum of building heat loss x 1.10*


*Ducts in conditioned space: sum of building heat loss x 1*

**Maximum Heat Equipment Output** 29,186 Btu / Hour

*Building and duct heat loss x 1.40 for forced air furnace*

*Building and duct heat loss x 1.25 for heat pump*

Figure 1.



## Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at [energycode@energy.wsu.edu](mailto:energycode@energy.wsu.edu) or (360) 956-2042 for assistance.

### Project Information

6717 42ND AVE S - RH24  
SEATTLE, WA 98118  
6848602-CN

### Contact Information

JW ARCHITECTS  
1257 S KING ST, SEATTLE, WA  
(206) 953-1305

### Heating System Type:

☐ All Other Systems

☒ Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

### Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference ( $\Delta T$ )

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

46

### Area of Building

#### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

1,497

#### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.5

Conditioned Volume

12,725

### Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA  
0.280 X 504 = 141.07

U-Factor X Area = UA  
0.50 X 0 = ---

### Skylights

[Instructions](#)

### Insulation

#### Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA  
No selection X 0 = ---

#### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

U-Factor X Area = UA  
0.027 X 608 = 16.42

#### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA  
0.056 X 2,609 = 146.09

#### Floors

[Instructions](#)

R-38

U-Factor X Area = UA  
0.025 X 15 = 0.38

#### Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

U-Factor X Area = UA  
0.042 X 326 = 13.70

#### Slab Below Grade (see Figure 1)

[Instructions](#)

R-21 int Plus R-5 ci

F-Factor X Length = UA  
0.303 X 47 = 14.33

#### Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Fully Insulated

F-Factor X Length = UA  
0.360 X 65 = 23.29

### Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient

1.00

Sum of UA 355.28

Envelope Heat Load 16,343 Btu / Hour

Sum of UA x  $\Delta T$

Air Leakage Heat Load 6,322 Btu / Hour

Volume x 0.6 x  $\Delta T$  x 0.018

Building Design Heat Load 22,664 Btu / Hour

Air leakage + envelope heat loss

Building and Duct Heat Load 22,664 Btu / Hour

Ducts in unconditioned space: sum of building heat loss x 1.10


Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 28,330 Btu / Hour

Building and duct heat loss x 1.40 for forced air furnace

Building and duct heat loss x 1.25 for heat pump

Figure 1.



## Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at [energycode@energy.wsu.edu](mailto:energycode@energy.wsu.edu) or (360) 956-2042 for assistance.

### Project Information

6717 42ND AVE S - RH25  
SEATTLE, WA 98118  
6848602-CN

### Contact Information

JW ARCHITECTS  
1257 S KING ST, SEATTLE, WA  
(206) 953-1305

### Heating System Type:

☐ All Other Systems

☒ Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

### Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference ( $\Delta T$ )

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

46

### Area of Building

#### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

1,494

#### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.5

Conditioned Volume

12,699

### Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA  
0.280 X 462 = 129.41

### Skylights

[Instructions](#)

U-Factor X Area = UA  
0.50 X 0 = ---

### Insulation

#### Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA  
No selection X 0 = ---

#### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

U-Factor X Area = UA  
0.027 X 619 = 16.71

#### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA  
0.056 X 2,655 = 148.65

#### Floors

[Instructions](#)

R-38

U-Factor X Area = UA  
0.025 X 20 = 0.49

#### Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

U-Factor X Area = UA  
0.042 X 133 = 5.60

#### Slab Below Grade (see Figure 1)

[Instructions](#)

R-21 int Plus R-5 ci

F-Factor X Length = UA  
0.303 X 39 = 11.82

#### Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Fully Insulated

F-Factor X Length = UA  
0.360 X 73 = 26.28

### Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient

1.00

Sum of UA 338.96

Envelope Heat Load 15,592 Btu / Hour

Sum of UA x  $\Delta T$

Air Leakage Heat Load 6,309 Btu / Hour

Volume x 0.6 x  $\Delta T$  x 0.018

Building Design Heat Load 21,901 Btu / Hour

Air leakage + envelope heat loss

Building and Duct Heat Load 21,901 Btu / Hour

Ducts in unconditioned space: sum of building heat loss x 1.10

Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 27,376 Btu / Hour

Building and duct heat loss x 1.40 for forced air furnace

Building and duct heat loss x 1.25 for heat pump

Figure 1.

