



October 17, 2023

Michael Larson  
Hewitt Architects

Subject: 1107 NE 45<sup>th</sup> St Excavation Shoring  
Project No. 6859479-CN Combined SDCI and SDOT Shoring Permit Comments

Dear Michael:

We have reviewed the Permit comments originally sent to us in July 2023 and resent September 25, 2023. As requested, we've compiled our responses to comments from all reviewers related to our scope in this single memo. Please refer to revised drawings and calculations dated October 17, 2023, for corrections referenced in our responses. Changes to the structural drawings have been clouded for your convenience. Please see our responses to comments below.

***Zoning: No comments applicable to KPFF shoring design team.***

***Land Use: No comments applicable to KPFF shoring design team.***

***Drainage: No comments applicable to KPFF shoring design team.***

***Geo Soils: No comments applicable to KPFF shoring design team.***

***Structural:***

1. *Comment: [Structural Special Inspections] SBC 1704.2.1 – Add a note to the plans: Special Inspection agencies and inspectors must be registered with the Washington Association of Building Officials (WABO).*

**Response: See note added to SHK0.001.**

**Remaining comments response by others.**

***SDOT:***

1. *Comment: Show 3 feet alley dedication line. Make sure the building will not be beyond the alley dedication line.*

**Response: Note, comment made on SHG1.001 but line also added to SHK1.100.**

If there are any further comments or questions, please feel free to call me at (206) 926-0672.

Sincerely,

A handwritten signature in blue ink that reads 'Eli Branch'.

Eli Branch, PE  
Project Engineer